

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7770-0328:144

Page 1 of 1

**CATEGORY:** Valves/Switches

**LISTEE:** Potter, 2081 Craig Road, St. Louis, MO 63146  
Contact: Brad Serangeli (314) 878-4321

**DESIGN:** Model BVS-1/2 in., BVS-3/4 in., BVS-1 in., supervised trim valves, \*Model RBVS, RBVS-T Retrofit Ball Valve Supervisory Switches. Units are intended to be installed in wet or dry sprinkler systems. The Model BVS and RDVS have an enclosure rating equivalent to a NEMA 4 rating. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 125 or 250 VAC, 15A

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as supervised trim valve for use with fire sprinkler systems.

\*Rev. 02-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager